

Applicant : APK Mühendislik Elektirk INŞ. San. Ve Tic. Ltd. ŞTI
Ivedik Organize Sanayi Bölgesi 29. Cad.
709.Sok. No:10-12 Yenimahalle
Ankara
Turkey

Application Date : January 8th, 2010

Order Number : 213233300

Subject : Short-circuit withstand test of main busbar panel

Trademark : APK

Type : 75 kA - 1s


Arnhem, February 17, 2010


Manufacturer/ Production sites : APK Mühendislik Elektirk INŞ. San. Ve Tic. Ltd. ŞTI
Ivedik Organize Sanayi Bölgesi 29. Cad.
709.Sok. No:10-12 Yenimahalle
Ankara
Turkey

Overview of tests : See Page 3

Test Requirements : IEC 60439-1:1999 and A1:2004
clause 8.2.3 (only main busbars)

Conclusion : The product complies with the specified requirements

Tested by : R. Verhagen 

Checked by : C.C. Burger 

RVer

0067-10

© KEMA Quality B.V. All rights reserved

Products may only be provided with a quality mark or put on the market as approved if KEMA Quality B.V. has explicitly granted the right to carry a quality mark.

KEMA Quality B.V. and/or its subsidiaries are not liable for any direct or indirect, incidental or consequential loss originating through or because of the use of the information or data from this document or due to the impossibility of using that information or data.

The contents of this report may not be made available to a third party other than as an entity provided with the aforementioned designations with respect to copyrights and liability.

KEMA Quality B.V., Utrechtseweg 310, 6812 AR Arnhem, The Netherlands, PO Box 5185, 6802 ED Arnhem, The Netherlands. Website www.kema.com www.BuyerRisk.com Telephone: +31 26 3 56 20 00. Telefax: +31 26 3 52 58 00.